

**ADDENDUM NO. 6**

**DOMINICA GEOTHERMAL RISK MITIGATION PROJECT II**

**TO BIDDING DOCUMENT**

**FOR**

**Design, Supply, and Installation**

**Procurement of**

***(i) New 2.2kV/11kV/33kV/69kV Substations and***

***(ii) New 11kV/33kV/69kV OHL and UGC***

***Transmission Lines***

***(Geothermal Power Plant to Fond Cole)***

**REFERENCE: DM-DGDC-384816-CW-RFB**

February 14, 2024

No.	Reference	Section	Original or Previous Amendment	Amended
1	Part II Section B Employer's Requirements  Underground Cables	6.2 Service Conditions	The specified cables shall be designed to meet a <b>25kA (1s)</b> earth fault duties for 69kV level.	The specified cables shall be designed to meet a <b>22.7 kA (1s)</b> earth fault duties for 69kV level.
2	Part II, Section B OHL, Clause 23	23. Provision of Training	The Contractor shall provide training as follows: a) Training at the Employer offices for PLS Cadd, PLS Pole, GIS Asset management. b) Provision of on-site training with regard to structure erection methods and emergency structure restoration.	The Contractor shall provide training as follows: a) Training at the Employer offices for PLS Cadd, PLS Pole, GIS Asset management. b) Provision of on-site training with regard to structure erection methods and emergency structure restoration.  Minimum requirements are as follows: For 5 Employer/DOMLEC staff: <ul style="list-style-type: none"> <li>• PLS Cadd: An accredited 4 day course from Power Line Systems, plus one 2 week one-on-one training on site, to be provided at the beginning of the project.</li> <li>• Global Mapper: A two-week one-on-one training on site, to be delivered at the beginning of the project.</li> </ul> For a team of 25 Employer/DOMLEC Staff: <ul style="list-style-type: none"> <li>• Provision of on-site training with regard to structure erection methods and emergency structure restoration</li> <li>• A three-week course shall be delivered to DOMLEC team, after delivery of the ERS structures.</li> </ul>

No.	Reference	Section	Original or Previous Amendment	Amended
3	ITB 23.1, as amended February 2, 2024 in Addendum No. 5.	C. Preparation of Bids Bid Submission (ITB 23.1) page 43.	<p>For Bid submission purposes only, the Employer's address is:</p> <p>Attention: Rita Destouches-Edmund Dominica Geothermal Development Company Limited Street Address: 18 Kennedy Avenue, Floor/ Room number: N/A City: Roseau ZIP/Postal Code: P.O. Box 1454 Country: Dominica</p> <p><b>The deadline for Bid submission is:</b></p> <p><b>Date: 29th February 2024</b></p> <p><b>Time: 14:00 hours (Dominica time/ GMT -4)</b></p> <p><b>Bidders shall not have the option of submitting their Bids electronically.</b></p>	<p>For Bid submission purposes only, the Employer's address is:</p> <p>Attention: Rita Destouches-Edmund Dominica Geothermal Development Company Limited Street Address: 18 Kennedy Avenue, Floor/ Room number: N/A City: Roseau ZIP/Postal Code: P.O. Box 1454 Country: Dominica</p> <p><b>The deadline for Bid submission is:</b></p> <p><b>Date: 29th March 2024</b></p> <p><b>Time: 14:00 hours (Dominica time/ GMT -4)</b></p> <p><b>Bidders shall not have the option of submitting their Bids electronically.</b></p>
4	ITB 26.1, as amended February 2, 2024 in Addendum No. 5.	E. Public Opening of Technical Parts of Bids Bid Opening (ITB 26.1) page 43	<p>The Bid opening shall take place Online via Microsoft Teams platform. Bidders may also attend in person at the address specified in ITB 7.1.</p> <p><b>Date: 29th February 2024</b></p> <p><b>Time: 14:00 hours (Dominica time/ GMT -4).</b></p>	<p>The Bid opening shall take place Online via Microsoft Teams platform. Bidders may also attend in person at the address specified in ITB 7.1.</p> <p><b>Date: 29th March 2024</b></p> <p><b>Time: 14:00 hours (Dominica time/ GMT -4).</b></p>
5	ITB 19.1, as amended February 2, 2024 in Addendum No. 5.	Bid Validity, page 42	<b>The Bid shall be valid until: August 24, 2024</b>	<b>The Bid shall be valid until: September 23, 2024</b>

No.	Reference	Section	Original or Previous Amendment	Amended
6	ITB 7.1	Bid clarifications	<p>For Clarification of Bid purposes only, the Employer's address is:</p> <p>Attention: Rita Destouches-Edmund, Finance and HR Manager</p> <p>Address: Dominica Geothermal Development Company Limited</p> <p>18 Kennedy Avenue, Roseau, Dominica</p> <p>Telephone: +767 448 6178/79</p> <p>Electronic mail address: transmissionepc@geodominica.com</p> <p><b>Requests for clarification should be received by the Employer no later than: Fourteen (14) days prior to the bid's submission deadline.</b></p> <p><b>Web page: <a href="https://www.geodominica.dm">https://www.geodominica.dm</a></b></p>	<p>For Clarification of Bid purposes only, the Employer's address is:</p> <p>Attention: Rita Destouches-Edmund, Finance and HR Manager</p> <p>Address: Dominica Geothermal Development Company Limited</p> <p>18 Kennedy Avenue, Roseau, Dominica</p> <p>Telephone: +767 448 6178/79</p> <p>Electronic mail address: transmissionepc@geodominica.com</p> <p><b>Requests for clarification should be received by the Employer no later than 29<sup>th</sup> February, 2024.</b></p> <p><b>Web page: <a href="https://www.geodominica.dm">https://www.geodominica.dm</a></b></p>